

DISCREPANCY REPORT FOR WEEK-36(2016-17)
(05.12.2016 to 11.12.2016)

I. ActiveEnergy Accounting.

1. Following main meter readings were replaced with Standby/Check meter readings due to non availability of main meter readings.

Sl.no	Loc.ID& SEM ID	Date	Location	Feeder/ICT	Repalced with LOC.ID& SEM Sl.no	Remarks
1	(CS-24) NP-2146-A	05.12.16 To 11.12.16	Korba(W)	400kV KSTPS line-I	(KO-15) NP-2541-A	DCD Problem
2	(LA-05) NP-9130-A	28.11.16 To 04.12.16	LARA(NTPC)	400KV Side of ST-1	(LA-13) NP-9186-A	DCD Problem
					(LA-16) NP-9187-A	

2. Following main meter readings were replaced with Standby/Check meter readings due to discrepancy in main meter readings.

Sl.no	Loc.ID& SEM ID	Date	Location	Feeder/ICT	Repalced with LOC.ID& SEM Sl.no	Remarks
1	(MM-54) NP-8709-A	07.12.16	Solapur(PG)	400KV side of ICT-2	(MM-53) NP-8706-A	Recorded zero reading for few blks

2.Following Adjustment values are added to the main meter data due to discrepancy in the Main meter data for few time blocks.

Sl.no	Loc.ID& SEM ID	Date	Time block	Location	Feeder/ICT	Name of Report where Adjustment value added
	NIL					

3. New Transmission Elements Synchronised with ISTS (Considered for accounting).

NIL

4. New Generating units Synchronised with ISTS (Considered for accounting)..

NIL

5. Generating units Declared CoD (Considered for accounting).

i) ACBIL has declared COD of Spectrum Unit#2 (50MW) wef 00:00hrs of 9th Dec'2016.

6.Duration of Non availability of Master frequency meter data at 400KV Korba STPS (Mahan line).

NIL

7.Congestion Application and withdrawal status.

NIL

8.Details of operation of SSP units in synchronous condenser mode.

Sl. No	Date	RBPH Unit under Synchronous Condenser Operation (SCO)	Time of Start in SCO(in Hrs)	Time of Stop in SCO(in Hrs)	Total SCO Hours
			WRLDC Code	WRLDC Code	
1	05.12.2016	1	5:00	6:40	6:35
			385	398	
		3	1:30	6:45	5:15
			389	398	
2	10.12.2017	2	0:45	5:35	4:50
			887	900	
3	11.12.2017	1	0:30	5:55	5:25
			989	1003	

9. CT/PT Errors Reported

NIL

9. Suspected meters that need to be replaced

NIL

II. ReactiveEnergy Accounting.

1.Following lines could not be included in REC accounts due to non availability of main meter readings.

i) ISTS-CSTPTCL: 400kV KSTPS line-I at Korba(W)