

Actual Active and Reactive energy Accounting for the week 06.06.16 to 12.06.16

I.Active Energy Accounting

1. Following changes are made in the accounting due to non availability/Discrepancies of Main Meter readings.

Sl.no	Date	Location	Feeder/ICT	Loc.ID& SEM Sl.no	Repalced with LOC.ID& SEM Sl.no	Remarks
1	06.06.16 To 12.06.16	RGPPPL	400kV Nagothane line-2	(RG-22) NP-6324-A	(RG-26) NP-6297-A	Time drift issue
2	06.06.16 To 12.06.16	Haldarwa	220kV KAPS-2	(GU-54) NP-4161-A	(KA-22) NP-2343-A	Data was corrupt
3	06.06.16	Gwalior(PG)	400kV side of ICT-1	(MP-13) NP-5748-A	(MP-14) NP-5749-A	Data was corrupt
4	09.06.16	Kolhapur	400KV Solapur(PG) line-2	(MM-28) NP-6713-A	(MM-27) NP-2651-A	Data was corrupt