

ANNEXURE

Actual Active and Reactive energy Accountig fwr the week 07.07.14 to 13.07.14**I.Active Energy Accounting**

1. Following changes are made in the accounting due to non availability/Discrepancies of Main Meter readings.

Sl.no	Date	Location	Feeder/ICT	Loc.ID& SEM Sl.no	Repalced with LOC.ID& SEM Sl.no	Remarks
1	07.07.14 to 13.07.14	Anuppur	200kv Kotmikala line 1	(MP-56) NP-2163-A	(CS-51) NP-2413-A	Data was corrupt
2	07.07.14 to 08.07.14	INDORE(MP)	400KV INDORE(PG) LINE-1 AT INDORE(MP)	(MB-56) NP-2624-A	(GG-72) NP-2778-A	Data not available
3	07.07.14 to 08.07.14	NAVSARI(PG)	400KV DGEN LINE-1 AT NAVSARI(PG)	(GG-70) NP-2781-A	(DG-21) GJ-2640-A	Data not available
4	07.07.14 to 10.07.14	Solapur	765KV Raichur line-2 at Solapur	(MM-57) NP-8710-A	(SR-12) NP-7170-A	Data not available
5	08.07.14	Bhadravati	400kv Line-1 to HVDC at Bhadravati(west bus)	(WR-31) NP-4165-A	(WR-33) NP-2310-A	Data was corrupt
6	08.07.14	Bhadravati	400kv Line-2 to HVDC at Bhadravati(west bus)	(WR-32) NP-4214-A	(WR-34) NP-4215-A	Data was corrupt
7	12.07.14	Wardha	400KV Side of ICT-3 AT Wardha	(MM-19) NP-6773-A	(MM-18) NP-6772-A	Data was corrupt
8	07.07.14	ESSAR HAZIRA	220KV SIDE OF ICT-2 AR ESSAR HAZIRA	(HZ-14) NP-2914-A	(HZ-12) NP-2915-A	Data not available

9	07.07.14 to 13.07.14	Sterlite(ER)	400kV Raigarh(PG) line-1 at Sterlite(ER)	(WR-45) NP-6539-A	(WR-37) NP-5928-A	Data not available
10	09.07.14	Budhipadar	220kV Korba line-1 at Budhipadar	(OR-56) NP-5940-A	(CS-56) NP-6774-A	Data was currrupt
11	09.07.14	Budhipadar	220kV Korba line-2 at Budhipadar	(OR-57) NP-5941-A	(CS-54) NP-2122-A	Data was currrupt
12	12.07.14	Dehgam	400kV Nagda line-2 at Dehgam	(GU-28) NP-5765-A	(MP-67) NP-2238-A	Data was currrupt
13	12.07.14	Dehgam	400kV Nagda line-1 at Dehgam	(GU-29) NP-5764-A	(MP-68) NP-2281-A	Data was currrupt