

1. Following changes are made in the accounting due to non availability/Discrepancies of Main Meter readings.

Sl.no	Date	Location	Feeder/ICT	Loc.ID& SEM Sl.no	Repalced with LOC.ID& SEM Sl.no	Remarks
1	10.02.14 TO 16.02.14	Anuppur	200kv Kotmikala line 1	(MP-56) NP-2163-A	(CS-51) NP-2413-A	Data was corrupted.Less energy recorded.
2	10.02.14 TO 16.02.14	RGPPL	400kv Nagothane line-2	(RG-22) NP-6327-A	(RG-26) NP-6297-A	Data not received.
3	10.02.14 TO 16.02.14	Balaghat	132kv Dongargarh line	(MP-85) NP-2156-A	(CS-82) NP-2349-A	Data not received.
4	10.02.14 TO 16.02.14	Jaypee Nigri	400KV SATNA LINE	(JY-13) NP-2948-A	(JY-14) NP-2949-A	Data was corrupted.Less energy recorded.
5	10.02.14	Solapur(PG)	400KV Kolhapur line-1	(MM-26) NP-2650-A	(MM-29) NP-6712-A	Data not received.
6	10.02.14	Solapur(PG)	400KV Kolhapur line-2	(MM-27) NP-2651-A	(MM-28) NP-6713-A	Data not received.
7	10.02.14	Solapur(PG)	400KV SIDE OF ICT-1	(MM-52) NP-8712-A	(MM-51) NP-8707-A	Data not received.
8	10.02.14	Solapur(PG)	400KV SIDE OF ICT-2	(MM-54) NP-8709-A	(MM-53) NP-8706-A	Data not received.
9	15.02.14.	Icchapur	200KV Kawas line-2	(GG-62) NP-2604-A	(KW-14) NP-2602-A	Data was corrupted.