

Actual Active and Reactive energy Accounting for the week 10.08.15 to 16.08.15

I.Active Energy Accounting

1. Following changes are made in the accounting due to non availability/Discrepancies of Main Meter readings.

Sl.no	Date	Location	Feeder/ICT	Loc.ID& SEM Sl.no	Repalced with LOC.ID& SEM Sl.no	Remarks
1	10.08.15 & 13.08.15 To 16.08.15	Bhadravati (west bus)	400kV Line-1 to HVDC	(WR-31) NP-4165-A	(WR-33) NP-2310-A	Data was corrupt
2	10.08.15 & 13.08.15 To 16.08.15	Bhadravati (west bus)	400kV Line-2 to HVDC	(WR-32) NP-4214-A	(WR-34) NP-4215-A	Data was corrupt
3	10.08.15 To 16.08.15	Zerda	400KV Ranchhodpura(Vadavi) Line-1	(GG-43) NP-6226-A	(GG-48) NP-6383-A	Data was not received
4	10.08.15 To 16.08.15	Zerda	400KV Ranchhodpura(Vadavi) Line-2	(GG-44) NP-6348-A	(GG-49) NP-6346-A	Data was not received