

1. Following changes are made in the accounting due to non availability/Discrepancies of Main Meter readings.

Sl.no	Date	Location	Feeder/ICT	Loc.ID& SEM Sl.no	Repalced LOC.ID& Sl.no	with SEM	Remarks
1	14.01.13 To 20.01.13	Indore	400KV Bina(PG) line	(MB-30) NP-2601-A	(MB-31) NP5760-A		Data was corrupted.
2	14.01.13 To 20.01.13	Chandrapur	400kV Bhadravati line-4	(MH-39) NP-2322-A	(MH-41) NP-2321-A		Data not received, line not in service.
3	14.01.13 To 20.01.13	IEPL	400kV Wardha line	(IE-12) NP-2386-A	(MD-21) NP-2637-A		Line not in service for the whole week
4	14.01.13	RGPPL	400kV Nagothane line 2	(RG-22) NP-6327-A	(RG-26) NP-6297-A		Erronious data recorded by SEM
5	15.01.13 To 20.01.13	Amarkantak	200kv Kotmikala line 1	(MP-56) NP-2163-A	(CS-51) NP-2413-A		Data not received.
6	14.01.13 To 20.01.13	Boisar(PG)	220kv TAPS 3&4 line.	(MH-58) NP-2218-A	(TA-52) NP-2225-A		Data not received.