

Actual Active and Reactive energy Accounting for the week 14.12.15 to 20.12.15

I.Active Energy Accounting

1. Following changes are made in the accounting due to non availability/Discrepancies of Main Meter readings.

Sl.no	Date	Location	Feeder/ICT	Loc.ID& SEM Sl.no	Repalced with LOC.ID& SEM Sl.no	Remarks
1	14.12.15 To 20.12.15	WARDHA	400kV Akola line-2	(MH-45) NP-6273-A	(MH-46) NP-6268-A	Data was not received
2	14.12.15 To 20.12.15	SSP	400kV Kasor line-1	(SS-21) NP-2554-A	(SS-22) NP-2552-A	Data was corrupt
3	14.12.15 To 20.12.15	RGPPL	400kV Nagothane line-2	(RG-22) NP-6327-A	(RG-26) NP-6297-A	Data was corrupt
4	19.12.15	TAMNAR(PS)	400KV JPL STG-2 LINE-4	(WR-62) NP-8689-A	(JD-21) NP-2876-A	Data was corrupt