

## ANNEXURE

**Actual Active and Reactive energy Accounting for the week 15.02.16 to 21.02.16****I.Active Energy Accounting****1. Following changes are made in the accounting due to non availability/Discrepancies of Main Meter readings.**

Sl.no	Date	Location	Feeder/ICT	Loc.ID& SEM Sl.no	Repalced with LOC.ID& SEM Sl.no	Remarks
1	15.02.16 To 21.02.16	Khadoli	220kV SAYALI line	(DN-87) NP-2925-A	(DN-80) NP-6412-A	Data was corrupt
2	15.02.16	RGPPL	400kV Nagothane line-2	(RG-22) NP-6327-A	(RG-26) NP-6297-A	Data was corrupt
3	15.02.16	Haldarwa	220kV KAPS-2	(GU-54) NP-4161-A	(KA-22) NP-2343-A	Data was corrupt
4	15.02.16 To 21.02.16	Kolhapur	400KV Solapur(PG) line-1	(MM-29) NP-6712-A	(MM-26) NP-2650-A	Data was not received
5	15.02.16 To 21.02.16	Kolhapur(GIS)	400KV Kudgi line-2	(PG-77) NP-8843-A	(PG-79) NP-9614-A	Data was not received
6	15.02.16 To 21.02.16	Kasor	400KV Rajgarh(PG) line-2	(PC-14) NP-2324-A	(PC-12) NP-6356-A	Data was not received
7	15.02.16 To 21.02.16	DHULE (MSETCL)	400KV DHULE (BDTCL) line-2 at	(PC-20) NP-9656-A	(BD-20) NP-8791-A	Data was not received
8	18.02.16 & 19.02.16	Bhadravati (west bus)	400kV Line-1 to HVDC	(WR-31) NP-4165-A	(WR-33) NP-2310-A	Data was corrupt
9	18.02.16 & 19.02.16	Bhadravati (west bus)	400kV Line-2 to HVDC	(WR-32) NP-4214-A	(WR-34) NP-4215-A	Data was corrupt
10	19.02.16	Bhadravathi	11kV supply from MSEB	(WR-84) NP-2319-A	(WR-85) NP-4216-A	Data was corrupt
11	20.02.16	Bhadravathi	11kV supply from MSEB	(WR-85) NP-4216-A	(WR-84) NP-2319-A	Data was corrupt