

Actual Active and Reactive energy Accounting for the week 15.09.14 to 21.09.14
I.Active Energy Accounting

1. Following changes are made in the accounting due to non availability/Discrepancies of Main Meter readings.

Sl.no	Date	Location	Feeder/ICT	Loc.ID& SEM Sl.no	Repalced with LOC.ID& SEM Sl.no	Remarks
1	15.09.14 to 21.09.14	Anuppur	200kv Kotmikala line 1	(MP-56) NP-2163-A	(CS-51) NP-2413-A	Data was corrupt
2	15.09.14 to 21.09.14	Bhadravati	400kv Line-1 to HVDC at Bhadravati	(WR-31) NP-4165-A	(WR-33) NP-2310-A	Data was corrupt
3	15.09.14 to 21.09.14	Bhadravati	400kv Line-2 to HVDC at Bhadravati	(WR-32) NP-4214-A	(WR-34) NP-4215-A	Data was corrupt
4	15.09.14 to 21.09.14	RGPPPL	400kv Nagothane line 2	(RG-22) NP-6327-A	(RG-26) NP-6297-A	Data not received
5	15.09.14 to 21.09.14	SEONI	400kv side of ICT 2 at Seoni	(MP-58) NP-5743-A	(MP-59) NP-5738-A	Meter recording 2/3 rd energy.
6	15.09.14 to 21.09.14	BILASPUR	400kv Lanco line 1	(LK-20) LT-0031-A	(LK-11) NP-6308-A	Data not received
7	15.09.14 to 21.09.14	BILASPUR	400kv Lanco line 2	(LK-21) LT-0033-A	(LK-13) NP-6313-A	Data not received