

**Actual Active and Reactive energy Accounting for the week 16.05.16 to 22.05.16**

**I.Active Energy Accounting**

**1. Following changes are made in the accounting due to non availability/Discrepancies of Main Meter readings.**

Sl.no	Date	Location	Feeder/ICT	Loc.ID& SEM Sl.no	Repalced with LOC.ID& SEM Sl.no	Remarks
1	16.05.16 To 22.05.16	RGPPL	400kV Nagothane line-2	(RG-22) NP-6324-A	(RG-26) NP-6297-A	Time drift issue
2	16.05.16 To 22.05.16	Haldarwa	220kV KAPS-2	(GU-54) NP-4161-A	(KA-22) NP-2343-A	Data was corrupt
3	16.05.16 To 22.05.16	Balghat	132kV Dongargarh line	(MP-85) NP-2156-A	(CS-82) NP-2349-A	Data was not received