

Actual Active and Reactive energy Accountig fwr the week 16.06.14 to 22.06.14

I.Active Energy Accounting

1. Following changes are made in the accounting due to non availability/Discrepancies of Main Meter readings.

Sl.no	Date	Location	Feeder/ICT	Loc.ID& SEM Sl.no	Repalced with LOC.ID& SEM Sl.no	Remarks
1	16.06.14 to 22.06.14	Anuppur	200kv Kotmikala line 1	(MP-56) NP-2163-A	(CS-51) NP-2413-A	Data not received
2	16.06.14 to 22.06.14	Anuppur	200kv Kotmikala line 2	(MP-57) NP-42283-A	(CS-52) NP-21553-A	Data not received
3	16.06.14 to 19.06.14	Raipur	400kv side of 400/220kv ICT-1	(CS-01) NP-2309-A	(CS-03) NP-2121-A	Data was corrupt.
4	16.06.14 to 19.06.14	Raipur	400kv side of 400/220kv ICT-2	(CS-03) NP-2327-A	(CS-04) NP-2143-A	Data was corrupt.
5	16.06.14 to 22.06.14	TAPS	400kV side of GT-3 at TAPS	(TA-05) NP-2228-A	(TA-15) NP-2149-A	Data not received
6	16.06.14 to 22.06.14	TAMNAR(PS)	400KV JPL STG-2 LINE-2 AT TAMNAR(PS)	(WR-61) NP-8693-A	(JD-19) NP-2873	Data not received
7	18.06.14	Shujalpur(PG)	400KV side of ICT-1 at Shujalpur(PG)	(MB-15) NP-6371-A	(MB-16) NP-6372-A	Data was corrupt.
8	16.06.14 to 22.06.14	Budhipadar	220kV Korba line- 2 at Budhipadar	(OR-57) NP-5941-A	(OR-58) NP-5944-A	Data was corrupt.
9	16.06.14 to 22.06.14	Bhachau	400kV Side of ICT-2 at Bhachau	(GG-41) NP-6442-A	(GG-42) NP-6385-A	Data not received