

Actual Active and Reactive energy Accounting for the week 19.01.15 to 25.01.15

I.Active Energy Accounting

1. Following changes are made in the accounting due to non availability/Discrepancies of Main Meter readings.

Sl.no	Date	Location	Feeder/ICT	Loc.ID& SEM Sl.no	Repalced with LOC.ID& SEM Sl.no	Remarks
1	19.01.15 to 25.01.15	Anuppur	200kv Kotmikala line 1	(MP-56) NP-2163-A	(CS-51) NP-2413-A	Data was corrupt
2	19.01.15 to 25.01.15	Korba(E)	220kV Budhipadar line-II	(CS-54) NP-2122-A	(OR-57) NP-5941-A	Data was corrupt
3	19.01.15 to 25.01.15	Bina(PG)	400kV side of 400/220kV ICT-01	(MB-11) NP-6845-A	(MB-12) NP-5721-A	Data was not received
4	19.01.15 to 25.01.15	Limbdi(Chornia)	400KV Ranchhodpura line-1	(GG-52) GJ-1207-A	(GG-46) NP-6434-A	Data was not received
5	19.01.15 to 25.01.15	Mansar (GETCO)	400KV Chorania line	(GR-16) NP-2777-A	(GG-55) NP-6428-A	Data was corrupt
6	19.01.15 to 25.01.15	Varsana (GETCO)	400KV Bhachau line 1	(GR-13) NP-2721-A	(GR-11) NP-6224-A	Data was not received
7	19.01.15 to 25.01.15	Varsana (GETCO)	400KV Bhachau line 2	(GR-14) NP-2722-A	(GR-12) NP-6219-A	Data was not received