

**Actual Active and Reactive energy Accounting for the week 23.05.16 to 29.05.16**

**I.Active Energy Accounting**

**I. Following changes are made in the accounting due to non availability/Discrepancies of Main Meter readings.**

Sl.no	Date	Location	Feeder/ICT	Loc.ID& SEM Sl.no	Repalced with LOC.ID& SEM Sl.no	Remarks
1	23.05.16 To 29.05.16	RGPPPL	400kV Nagothane line-2	(RG-22) NP-6324-A	(RG-26) NP-6297-A	Time drift issue
2	23.05.16 To 29.05.16	Haldarwa	220kV KAPS-2	(GU-54) NP-4161-A	(KA-22) NP-2343-A	Data was corrupt
3	23.05.16	Kawas	220kV Navsari line-1	(KW-15) NP-2275-A	(GG-69) NP-2772-A	Data was not received
4	25.05.16	Kolhapur	400kV Kolhapur(GIS) Line-1	(MH-32) NP-2451-A	(PG-75) NP-8842-A	SEM calibration was done
5	25.05.16	Kolhapur	400kV Kolhapur(GIS) Line-2	(MH-33) NP-2400-A	(PG-74) NP-8844-A	SEM calibration was done