

**1. Following changes are made in the accounting due to non availability/Discrepancies of Main Meter readings.**

| <b>Sl.no</b> | <b>Date</b>                | <b>Location</b> | <b>Feeder/ICT</b>           | <b>Loc.ID&amp; SEM Sl.no</b> | <b>Repalced with LOC.ID&amp; SEM Sl.no</b> | <b>Remarks</b>                           |
|--------------|----------------------------|-----------------|-----------------------------|------------------------------|--|--|
| 1            | 24.02.14<br>TO<br>02.03.14 | Anuppur         | 200kv Kotmikala line 1      | (MP-56)<br>NP-2163-A         | (CS-51)<br>NP-2413-A                       | Data was corrupted.Less energy recorded. |
| 2            | 24.02.14<br>TO<br>02.03.14 | Balaghat        | 132kV Dongargarh line       | (MP-85)<br>NP-2156-A         | (CS-82)<br>NP-2349-A                       | Data not received.                       |
| 3            | 24.02.14<br>TO<br>02.03.14 | Jaypee Nigri    | 400KV Satna line            | (JY-13)<br>NP-2948-A         | (JY-14)<br>NP-2949-A                       | Data was corrupted.Less energy recorded. |
| 4            | 24.02.14<br>TO<br>02.03.14 | RGPPL           | 400kV Nagothane line-2      | (RG-22)<br>NP-6327-A         | (RG-26)<br>NP-6297-A                       | Data not received.                       |
| 5            | 25.02.14                   | Damoh           | 400kV Bhopal line-1         | (DM-23)<br>NP-6850-A         | (MP-84)<br>NP-2553-A                       | Data was corrupted                       |
| 6            | 24.02.14                   | Damoh           | 400kV Birsingpur(PG) line-1 | (DM-25)<br>NP-6854-A         | (MB-25)<br>NP-6847-A                       | Data was corrupted                       |
| 7            | 24.02.14                   | Damoh           | 400kV Birsingpur(PG) line-2 | (DM-26)<br>NP-6852-A         | (MB-26)<br>NP-6848-A                       | Data was corrupted                       |