

Actual Active and Reactive energy Accounting for the week 27.06.16 to 03.07.16
I.Active Energy Accounting

1. Following changes are made in the accounting due to non availability/Discrepancies of Main Meter readings.

Sl.no	Date	Location	Feeder/ICT	Loc.ID& SEM Sl.no	Repalced with LOC.ID& SEM Sl.no	Remarks
1	27.06.16 To 03.07.16	RGPPL	400kV Nagothane line-2	(RG-22) NP-6324-A	(RG-26) NP-6297-A	Time drift issue
2	27.06.16 To 03.07.16	Haldarwa	220kV KAPS-2	(GU-54) NP-4161-A	(KA-22) NP-2343-A	Data was corrupt
3	27.06.16	Aurangabad (MSEB)	400kV Aurangabad(PG) Line-1	(MH-49) NP-8864-A	MM-55 NP- 8743-A	Meter was replaced
4	30.06.16 To 03.07.16	Wardha(PG)	400KV Mauda(NTPC) line-2	(MM-14) NP-2826-A	MD-22NP- 2638-A	Data was corrupt
5	03.07.16	Ichhapur	200KV Kawas line-2	(GG-62) NP-2604-A	KW-14NP- 2602-A	Data was corrupt