

1. Following changes are made in the accounting due to non availability/Discrepancies of Main Meter readings.

Sl.no	Date	Location	Feeder/ICT	Loc.ID& SEM Sl.no	Repalced LOC.ID& Sl.no	with SEM	Remarks
1	28.01.13 To 03.02.13	Indore	400KV Bina(PG) line	(MB-30) NP-2601-A	(MB-31) NP5760-A		Data was corrupted.
2	28.01.13 To 03.02.13	IEPL	400kv Wardha line	(IE-12) NP-2386-A	(MD-21) NP-2637-A		Line not in service for the whole week
3	28.01.13 To 03.02.13	RGPPPL	400kv Nagothane line 2	(RG-22) NP-6327-A	(RG-26) NP-6297-A		Erronious data recorded by SEM
4	28.01.13 To 03.02.13	Amarkantak	200kv Kotmikala line 1	(MP-56) NP-2163-A	(CS-51) NP-2413-A		Data not received.
5	31.01.13	Bhatapara	400kv side ICT-1	(CS-11) NP-6312-A	(CS-12) NP-6307-A		Data was corrupted.