

**Actual Active and Reactive energy Accounting for the week 30.05.16 to 05.06.16**  
**I.Active Energy Accounting**

**1. Following changes are made in the accounting due to non availability/Discrepancies of Main Meter readings.**

Sl.no	Date	Location	Feeder/ICT	Loc.ID& SEM Sl.no	Repalced with LOC.ID& SEM Sl.no	Remarks
1	30.05.16 To 05.06.16	RGPPPL	400kV Nagothane line-2	(RG-22) NP-6324-A	(RG-26) NP-6297-A	Time drift issue
2	30.05.16 To 05.06.16	Haldarwa	220kV KAPS-2	(GU-54) NP-4161-A	(KA-22) NP-2343-A	Data was corrupt
3	04.06.16 & 05.06.16	Gwalior(PG)	400kV side of ICT-1	(MP-13) NP-5748-A	(MP-14) NP-5749-A	Data was corrupt
4	04.06.16	Solapur	765KV Raichur line- 1	(MM-44) NP-8711-A	(SR-11) NP-7172-A	Data was corrupt
5	01.06.16	Mapussa	400kV side of ICT-1	(GO-01) NP-2419-A	(GO-02) NP-2469-A	SEM calibration was done
6	03.06.16	Mapussa	400kV side of ICT-2	(GO-03) NP-2348-A	(GO-04) NP-2232-A	SEM calibration was done
7	30.05.16 To 05.06.16	Morba	132KV Bina-UP line	(MB-71) NP-2941-A	(UP-33) NP-1286-A	Data was not received
8	30.05.16	Balghat	132kV Dongargarh line	(MP-85) NP-2156-A	(CS-82) NP-2349-A	Data was corrupt