



Power System Operation Corporation Limited
Western regional Load Despatch Centre
FLASH REPORT

MESSAGE NO- LD/04/2580

DATE:-25/04/2014

Incident:

1. Date and Time: 25.04.14 and 19:25 HRS

2. ANTECEDENT Conditions

I. Frequency of NEW Grid

Event	Frequency	Time(hh:mm)
Pre incident	49.89	19:24
Post Incident	49.95	19:26

II. Demand Met

Sl.No	Area/Region	Demand Met(MW)
1	WR	40543
2	Gujarat	11576
3	Maharashtra	17414
4	Madhya Pradesh	6578
5	Chhattisgarh	3376
6	Goa	460
7	DD	247
8	DNH	647
9	ESIL	245

3. Elements affected:

Sr No.	Name of the Element	Outage Time	Restoration time	Remark
1	400 KV BHOPAL-DAMOH-I	19:25	20:45	B-E FAULT
2	400 KV BHOPAL-DAMOH-II	19:25	20:50	Y-B FUALT
3	400 KV BHOPAL(MP)- BINA(MP)-I	19:25	20:37	Reason awaited
4	400/220kV ICT-I at BHOPAL	19:25	Still Out	CB FIRE
5	400/220kV ICT-II at BHOPAL	19:25	20:24	Reason awaited
6	400/220kV ICT-III at BHOPAL	19:25	20:24	Reason awaited

3. Areas Affected By Disturbance

NIL

4. Actions Taken:

Restoration started immediately. ICTs II & III restored at 20:24hrs.

(Shift Charge Manager)

Distribution:

S/I : NLDC, SLDC- GETCO, MPPTCL, MSETYCL, CSPTCL, GOA, DD, DNH, Control
room: NTPC, CGPL
AGM/GM-WRLDC, MS-WRPC