



**Power System Operation Corporation Limited**  
**Western regional Load Despatch Centre**  
**FLASH REPORT**

MESSAGE NO- LD/04/2777

DATE:-27/04/2014

**Incident:**

1. Date and Time: 27.04.14 /17:56 HRS

2. ANTECEDENT Conditions

I. Frequency of NEW Grid

Event	Frequency	Time(hh:mm)
Pre incident	50.09	17:52
Post Incident	50.21	18:10

II. Demand Met

Sl.No	Area/Region	Demand Met(MW)
1	WR	36221
2	Gujarat	11600
3	Maharashtra	14422
4	Madhya Pradesh	5610
5	Chhattisgarh	3019
6	Goa	288
7	DD	273
8	DNH	645
9	ESIL	332

3. Elements affected:

Sr No.	Name of the Element	Outage Time	Restoration time	Remark
1	400/220kV ICT-3 at INDORE	17:56	Still Out	Y PH CT of 220 KV Indore-Indore line BURST
2	400/220kV ICT-4 at INDORE	17:56	18:27	Y PH CT of 220 KV Indore-Indore line BURST
3	220 KV INDORE (MP)-INDORE (MP)	17:56	Still Out	Y PH CT of 220 KV Indore-Indore line BURST

### **3. Areas Affected By Disturbance**

Load Loss around 502 MWs. Restoration started immediately

### **4. Actions Taken:**

ICTs 4 restored at 18:27 Hrs. ICT 3 likely to be charged.

**(Shift Charge Manager)**

### **Distribution:**

**S/I : NLDC, SLDC- GETCO, MPPTCL, MSETYCL, CSPTCL, GOA, DD, DNH, Control  
room: NTPC, CGPL  
AGM/GM-WRLDC, MS-WRPC**