

पुस्तिका संख्या :

Book No. :

75

पावर सिस्टम ऑपरेशन कारपोरेशन लिमिटेड

(पावरग्रिड की एक पूर्ण स्वामित्व वाली कंपनी)

पश्चिम क्षेत्रिय भार प्रेषण केन्द्र, मुम्बई

Power System Operation Corporation Ltd.

(A Wholly owned subsidiary company of POWERGRID)

Western Regional Load Despatch Centre, Mumbai

अनुक्रमांक :

Sr. No. 7439



फॅक्स संदेश

FAX MESSAGE

संदेश संख्या : भाप्रे /~~11~~/

Msg.No. : LD /04/ 2343

दिनांक : / / 20

Date : 23/04/2014

समय : : घंटे

Date : 13:23 hrs

प्रेषक / From : SCM, WRLDC, POSOCO, MUMBAI

प्रती / To :

- 1) SCM, NLDC / ERLDC / NRLDC / SRLDC / NERLDC
- 2) SCM, SLDC, CSPTCL / GETCO / MPPTCL / MSETCL / GOA / DD / DNH
- 3) SCM, NTPC / NPC-TAPS-KAPS / SSP / NSPCL / RGPPL
- 4) SCM, JPL / LANCO

प्रतिलिपी / Copy To :

- 1) SCM, NLDC / ERLDC / NRLDC / SRLDC / NERLDC
- 2) SCM, SLDC, CSPTCL / GETCO / MPPTCL / MSETCL / GOA / DD / DNH
- 3) SCM, NTPC / NPC-TAPS-KAPS / SSP / NSPCL / RGPPL / JPL / LANCO
- 4) CEO-GM-AGM, POSOCO / M.S.-S.E.(O), WRPC

NLDC, POSOCO

विषय :

Sub : Sudden load drop in Maharashtra system.

AS intimated by MSETCL, at 1029 hrs 220kV Kandalgaon-Sona Alloy line was tripped due to isolator sparking and 220kV Sejuri-Lorand and Sejuri-Baramati tripped on overcurrent. It was intimated that about 350MW load was thrown off (i) The lines were restored as under

Sejuri-Lorand 1106 hrs

Sejuri-Baramati at 1110 hrs
exact time not known

Kandalgaon-Sona Alloy line remained out further details awaited from MSETCL, Kalwa (i)

For kind intimation

musaliw@ma

(पारी प्रभारी)

(Shift Charge Manager)

राष्ट्रहित में ऊर्जा बचाएँ।