

To All Concerned,

As intimated by SLDC, Jabalpur, MP , Y-ph CT of 220 kV Malanpur-Mehgaon line at Mehgaon end burst at 01:05hrs /04-04-2016 resulting in tripping of 220kV Mehgaon-Auraiya line also. This in turn resulted in load interruption of about 70 MW at Mehgaon which was restored through 132kV Malanpur-Mehgaon line (which is kept in general in open condition) at 01:25hrs.

Regards. WRLDC