

FAX MESSAGE



MADHYA PRADESH POWER TRANSMISSION COMPANY LIMITED
STATE LOAD DESPATCH CENTRE
 NAYAGAON, RAMPUR, JABALPUR - 482008
 Phone: (0761) 2706800, 2701500, 2668535, 2660015 Fax: (0761) 266134
 e-mail : sldcmpseb@yahoo.com website : www.sldcmpindia.com



आई एन ओ : 9001-2008
 ISO: 9001-2008

FROM:	TO:
SHIFT INCHARGE	S/I WR LDC
SLDC, MPPTCL, JABALPUR	Mumbai
	FAX NO.

No. 07-05/CR/ Tripping Report of Sukha 220kV (Date 15/5/16)
 SUBJECT: s/s Time: 20:00
 REF: 220 Sukha-Panaga end

At 17:15 hrs. RΦ CT blast at 220 s/s Sukha.
 Due to this Bus fault occurred & following feeders tripped

- (1) Narsingpur ckt I & II
- (2) Jabalpur 220 ckt I & II
- (3) 220kv Panaga end I. (4) Bus tie.

Indication of the feeders are as given below:-

Narsingpur ckt I - F.W - trip ckt fail
 Relay - Trip ckt Separation trip.

Narsingpur ckt II - DPR opt, ΦBN, Z-1, CRT, CT, Weak FT-1,
 10km, 14 to trip ΦB

ATN Pan-end - DPR optd. Distribution failure optd. ΦRN, trip ABC,
 CRT, CT, Weak FT-1,

Panaga I - ΦRN, Z-1, FT-1, trip ABC, DPR optd.

At Panaga end - DPR optd. ΦABC, Zone-2, Master trip
 11.3km.

Jabalpur I & II - No indications at Sukha end.
 At Jabalpur end - No tripping No indications.

[Signature]
 SHIFT INCHARGE,
 State Load Dispatch Centre,
 MPPTCL, Jabalpur