



मध्यप्रदेश पावर ट्रांसमिशन कम्पनी लिमिटेड

OR-28

क्र.....

दिनांक.....

प्रेषक,

₹ 220kV S/S

प्रति,

To, S/O

Damoh.

WRLDC

MPPTCL

Mumbai

विषय:

संदर्भ: Regarding tripping at 220kV S/S Damoh.

At 220kV S/S Damoh, at 10.00hrs
25/05/16 ~~Bus~~ Bus bar protection
operated so following ckt
got tripped

220kV Damoh - Katni

220kV Damoh - Traction I & II

220kV Damoh - Tikamgarh

220kV Damoh (P/G) - Damoh MP I & II

~~So kindly~~ 220kV Damoh (P/G) - MP - II
got tripped after sometime
therefore it may be the reason
for Bus bar protection operation.

So for managing the load kindly allow
to charge 220kV Damoh (P/G) - MP - I
are ready to charge.

MPPTCL
Load Department
P/971/Yr.-10