



WRLDC Control Room <wrlcdcposoco@gmail.com>

220KV Bus- 2 fault at Chhegaon (MP) S/S

WRLDC Control Room <wrlcdcposoco@gmail.com>

Mon, Oct 17, 2016 at 2:01 AM

To: SLDC MPSEB Gmail <sldcmpjbp@gmail.com>, SLDC MPSEB Yahoo <sldcmpseb@yahoo.com>

Cc: Abhimanyu Gartia <agartia@gmail.com>, Aditya P Das <aditya19227@gmail.com>, Chandan Kumar <chandan8240000@gmail.com>, Chitranshi Ghangrekar <chitra_20j@yahoo.com>, Muralikrishna Kodakandla <mkkodakandla@gmail.com>, Pushpa Seshadri <pushpa_seshadri@hotmail.com>, Vivek Pandey <vivek.pandey@posoco.in>, WRLDC Outage Gmail <wrlcdcoutage@gmail.com>, WRLDC Reliability <wrlcdc reliability@gmail.com>

Sir,

At 01:14hrs 220KV Bus-2 fault occurred due to Bus CVT blasted at Chhegaon S/s and all originating 220KV lines tripped which is given below:-

1. 220Kv Chhegaon- Khandwa-1 & 2
2. 220Kv Chhegaon- Singhaji-1 & 2
3. 220KV Chhegaon- Nimrani-2
4. 220KV Chhegaon- Neapanagar

As per SLDC MPSEB there is no any load loss occurred in Chhegaon area. MPSEB requested to kindly forward the flash report.

R K Bhoi
SCM WRLDC

पा.प्र. सं. (SCM)
नियंत्रण कक्ष (Control Room)
पश्चिम क्षेत्रीय भार प्रेषण केंद्र, मुंबई
(Western Regional Load Despatch Centre, Mumbai)
संपर्क (Contact) - 022-28203885, 28397634
पन. कॉम (PUNCOM) - 500-112, 113, 114, 115
ऑरेंज (ORANGE)- 20220033, 55, 44
फैक्स (FAX) - 022-28202630, 93
पन. कॉम फैक्स (PUNCOM FAX) - 500101

Information contained and transmitted by this email is confidential and proprietary to The Power System Operation Corporation Ltd. and is included for use only by the addressee. If you are not the intended recipient, you are notified that any dissemination or copying of this email or contents therein is strictly prohibited. If this message is not intended for you, then you are requested to delete this email immediately and notify the originator.