

FAX MESSAGE



MADHYA PRADESH POWER TRANSMISSION COMPANY LIMITED
STATE LOAD DESPATCH CENTRE
 NAYAGAON, RAMPUR, JABALPUR - 482008

Phone: (0761) 270581, 270590, 270591, 266005 Fax: (0761) 2664343
 e-mail: sldc.m.p@nptcl.com website: www.sldcmppn.org



FROM: SHIFT INCHARGE SLDC, MPPTCL, JABALPUR	TO: S/I, WRLOE Mumbai
--	---------------------------------

No. 07-05/CR/

Alarm Report -

DATE 19/11/2016
 TIME: 9.00 HRS

At 01:20 hrs/19.11.16 Bus Bar protection of Bus 'A' operated at 220kV Omkarnagar-H/S, when desynchronization command executed for 4#3 (SF6 gas pressure low).
 Following feeders tripped on B/B protection:-

	Time of tripping	Time of Restoration
① 220kV Omkarnagar tap Bunka Nirran ckt.	01:20	02:31 hr.
② 220kV Omkarnagar - Tulwaniya ckt	01:20	02:32 hrs
③ 220kV Omkarnagar - Khandwa ckt	01:20	02:45 hrs
④ 220kV Bus-Coupler.	01:20	02:20 hr

There is no interruption & no load loss in any area.

[Signature]
 SHIFT INCHARGE
 State Load Despatch Centre
 MPPTCL, Jabalpur