

Regarding tripping of 220kV lines from Amona

WRLDC Control Room

Sent: 08 February 2017 05:19

To: GOA ELECTRICITY [220kvged@gmail.com]; SLDC MSEB [cesldc@mahasldc.in]; MSLDC Outages [msldc_outage@mahasldc.in]; msldcoutage@gmail.com; CPCC Nagpur (wr1rtamc@powergrid.co.in)

Cc: K Muralikrishna; Pushpa S; Vivek Pandey; Chitranshi Ghangrekar; WRLDC Protection; Chandan Kumar

Sir,

As reported by CPCC Nagpur/Goa at 04:10 Hrs following 220kV lines tripped-

1. 220kV Mapusa-Amona-S/c
2. 220kV Mahalakshmi-Amona-S/c
3. 220kV Tillari-Amona-S/c
4. 220kV Mapusa-Ponda-S/c

May kindly furnish the details of the tripping along with DR/EL at earliest.
Also expedite the restoration of the 220kV Mapusa-Amona-S/c line.

Goa is also requested to send the flash report of the event.

Regards
Pradeep
WRLDC Mumbai