

## Srinivas Chituri

---

**From:** WRLDC Protection  
**Sent:** 26 February 2017 00:40  
**To:** Srinivas Chituri  
**Subject:** Fwd: ꣳGOA's Major 220kv Ckts Bdn&LOAD Lossꣳ  
**Attachments:** Occurrence Report.docx; ATT00001.htm

Regards,  
Chandan

Begin forwarded message:

**From:** WRLDC Control Room <[wrldccr@posoco.in](mailto:wrldccr@posoco.in)>  
**Date:** 25 February 2017 at 2:10:07 PM IST  
**To:** WRLDC Protection <[protectionwrldc@posoco.in](mailto:protectionwrldc@posoco.in)>  
**Subject:** FW: ꣳGOA's Major 220kv Ckts Bdn&LOAD Lossꣳ

For information please

**From:** GOA ELECTRICITY [<mailto:220kvged@gmail.com>]  
**Sent:** 25 February 2017 14:01  
**To:** CEE-GED Vidyut Bhavan. <[cee-elec.goa@nic.in](mailto:cee-elec.goa@nic.in)>; CLD Bangalore <[ceeldckptcl@gmail.com](mailto:ceeldckptcl@gmail.com)>; SMK-Idea <[vsmk1960@gmail.com](mailto:vsmk1960@gmail.com)>; SRLDC Bangalore <[srldccroom@gmail.com](mailto:srldccroom@gmail.com)>; Station Mobile <[220kvged@gmail.com](mailto:220kvged@gmail.com)>; Sudhir.JE <[sudhiratrupeemail@gmail.com](mailto:sudhiratrupeemail@gmail.com)>; WRLDC Control Room <[wrldccr@posoco.in](mailto:wrldccr@posoco.in)>  
**Subject:** Re: ꣳGOA's Major 220kv Ckts Bdn&LOAD Lossꣳ

With MP-I Relay details

Regards  
AEE 220KV Station  
Div-III, Goa

On 25 February 2017 at 13:19, GOA ELECTRICITY <[220kvged@gmail.com](mailto:220kvged@gmail.com)> wrote:

----- Forwarded message -----

**From:** GOA ELECTRICITY <[220kvged@gmail.com](mailto:220kvged@gmail.com)>  
**Date:** 25 February 2017 at 13:18  
**Subject:** Re: ꣳGOA's Major 220kv Ckts Bdn&LOAD Lossꣳ  
**To:** Mohankrishna Srinivasan <[vsmk1960@gmail.com](mailto:vsmk1960@gmail.com)>

On 25 February 2017 at 12:12, <[vsmk1960@gmail.com](mailto:vsmk1960@gmail.com)> wrote:

\*#GOA's Major 220kv Ckts Bdn&LOAD Loss#\*.

Dear Sir,

Good-Mrg.

\*#Today morning due to tripping of MP-I&KP-I Ckts 220kv BUS-I was DEAD for @10mins betn 06.15/6.25hrs with a load loss of @75mw thus interrupting Ponda, Verna&OPA water works as single 220kv Ckt TLR/Amona was available#\*.

\*Subsequently there was TOTAL BLACK-OUT of Ponda Station for @05mins throwing out @220mw of loads betn 06.49/06.54hrs due to Transient tripping of available lone Ckt ie TLR/Amona.Now on REAL TIME STATUS 220kv MP-2&TP-2 are in service catering normal loads @250mw.MP-I &KP-I Ckts have been declared faulty.Expected to restore prior to Evg-Peakhrs#\*.

\*North GOA ie TIVIM Station catered from 220kv MT-I/II&South GOA ie XELDEM catered from SR Grid were not affected\*.

With Regards.

[SM.Krishna.  
220kv Station].