

	II									
26	MAPUSA-AMONA-S/C	Line	220 kV	GOA	16-03-2017	06:18	16-03-2017	06:56	-	B-N Fault
27	MAPUSA- PONDA-I	Line	220 kV	GOA	16-03-2017	06:18	16-03-2017	16:55	-	B-N fault
28	Vadodra Bus 2 BUS II	Bus	220 kV	PGCIL	01-01-1900	00:00	22-03-2017	18:28	-	First time charging
29	400/1200KV ICT-1 AT BINA(PG)	ICT	1200/400 kV	PGCIL	12-03-2017	06:31	*	*	NA	BUCHHHOLTZ OPERATED ON ICT-2/ 1200KV SYSTEM BYPASSED LATER
30	400/1200KV ICT-2 AT BINA(PG)	ICT	1200/400 kV	PGCIL	12-03-2017	06:31	*	*	NA	BUCHHHOLTZ OPERATED

\*-Line still under outage NA - Not Available

### C. Details of Transmission Elements under Emergency Outage:-

S.No	Element Name	Type	Voltage Level	Owner	Outage		Revival		Expected Date of Revival	Reason / Remarks
					Date	Time	Date	Time		
1	CHANDRAPUR-PADGHE POLE-II	Line	500 kV HVDC	MSETCL	16-03-2017	23:39	17-03-2017	00:51	-	to attend hot spots observed on capacitor bank at Padghe end
2	KAKRAPAR-VAPI-I	Line	400 kV	PGCIL	28-02-2017	12:36	19-03-2017	09:56	-	To attend defects in line
3	VAPI-KAKRAPAR-II	Line	400 kV	PGCIL	28-02-2017	12:56	19-03-2017	09:56	-	To attend defects in line
4	VAPI-KALA-II-II	Line	400 kV	PGCIL	16-03-2017	17:13	16-03-2017	18:45	-	To attend SF6 gas leakage
5	BACHHAU-VADAVI-I	Line	400 kV	PGCIL	16-03-2017	23:04	17-03-2017	00:23	-	remove cloth hanging between middle and bottom conductor
6	ASOJ ICT-1	ICT	400/220 kV	GETCO	16-03-2017	09:30	16-03-2017	18:35	-	attending Hot Points on 33kV bushing
7	VARSANA ICT-1	ICT	400/220 kV	GETCO	16-03-2017	09:45	16-03-2017	12:55	-	HOT POINTS

\*-Line still under outage NA - Not Available

### D. Details of Transmission Elements under Voltage Regulation outage:-

S.No	Element Name	Type	Voltage Level	Owner	Outage		Revival		Expected Date of Revival	Reason / Remarks
					Date	Time	Date	Time		
1	Koradi(3) 240MVAR BR	Bus Reactor	765 kV	ATIL	16-03-2017	05:59	16-03-2017	22:18	-	Voltage Regulation
2	Bilaspur(PG) 240MVAR BR	Bus Reactor	765 kV	PGCIL	16-03-2017	06:13	19-03-2017	13:32	-	Voltage Regulation
3	Sasan 240MVAR BR	Bus Reactor	765 kV	SASAN	16-03-2017	06:23	*	*	NA	Voltage Regulation
4	SIPAT(NTPC) 240MVAR BR	Bus Reactor	765 kV	NTPC	16-03-2017	06:30	18-03-2017	13:44	-	Voltage Regulation
5	Bhopal(BDTCL) 240MVAR BR	Bus Reactor	765 kV	Sterlite	16-03-2017	06:33	16-03-2017	17:48	-	Voltage Regulation
6	AKOLA(2) 240MVAR BR	Bus Reactor	765 kV	ATIL	16-03-2017	06:48	16-03-2017	17:47	-	Voltage Regulation
7	Aurangabad(III)(Ektuni-MSETCL) 240 MVAR BR	Bus Reactor	765 kV	MSETCL	16-03-2017	06:50	16-03-2017	17:48	-	Voltage Regulation
8	INDORE-PG 240MVAR BR-1	Bus Reactor	765 kV	PGCIL	16-03-2017	07:42	16-03-2017	22:09	-	Voltage Regulation
9	Satna(PG) 240MVAR BR-1	Bus Reactor	765 kV	PGCIL	16-03-2017	07:43	16-03-2017	23:57	-	Voltage Regulation
10	Seoni(PG) 240MVAR BR	Bus Reactor	765 kV	PGCIL	16-03-2017	11:21	16-03-2017	20:02	-	Voltage Regulation
11	PUNE GIS 240MVAR BR	Bus Reactor	765 kV	PGCIL	16-03-2017	11:23	16-03-2017	17:38	-	Voltage Regulation
12	Betul GIS (PG) 125MVAR BR	Bus Reactor	400 kV	PGCIL	11-03-2017	06:46	*	*	NA	Voltage Regulation
13	GWALIOR-1 (125MVAR) BR	Bus Reactor	400 kV	PGCIL	16-03-2017	06:20	17-03-2017	00:36	-	Voltage Regulation
14	GWALIOR-2 (125MVAR) BR	Bus Reactor	400 kV	PGCIL	16-03-2017	06:21	17-03-2017	00:36	-	Voltage Regulation
15	SUJALPUR-1 (63MVAR) BR	Bus Reactor	400 kV	PGCIL	16-03-2017	07:42	16-03-2017	17:56	-	Voltage Regulation
16	SUJALPUR-2 (125MVAR) BR	Bus Reactor	400 kV	PGCIL	16-03-2017	07:43	16-03-2017	17:56	-	Voltage Regulation
17	KOLHAPUR (80MVAR) BR	Bus Reactor	400 kV	PGCIL	16-03-2017	09:35	16-03-2017	17:25	-	Voltage Regulation
18	PUNE (50MVAR) BR	Bus Reactor	400 kV	PGCIL	16-03-2017	10:33	16-03-2017	17:31	-	Voltage Regulation
19	MAGARWARA 80MVAR BR	Bus Reactor	400 kV	PGCIL	16-03-2017	15:36	17-03-2017	00:33	-	Voltage Regulation
20	KALA (80MVAR) BR	Bus Reactor	400 kV	PGCIL	16-03-2017	15:38	17-03-2017	00:30	-	Voltage Regulation
21	SEONI-KHANDWA FSC-2 FSC	FSC	400 kV	PGCIL	16-03-2017	19:54	17-03-2017	05:20	-	Voltage