

Reg Tripping of 400KV Lines at B'Blswr S/s

WRLDC Control Room

Sent: 18 March 2017 16:52**To:** cesldc@mahasldc.in**Cc:** WRLDC Reliability; WRLDC Protection

Sir,

It is observed from SCADA that following 400KV Lines / ICT's have tripped
At B'Blswr S/s at 1630Hrs .

1. Dhule-2
2. Abad – S/c
3. Padghe-2
4. 400/220KV ICT-2 & 3

Please inform the reasons for tripping And also Load Loss if any.

Matter urgent please

SCM WRLDC