

FLASH REPORT

CGLD/06/890

DATE 25/06/2017

Time: 13:15 Hrs

Incident: Tripping of 220KV KWB-CHHURI LINE- I&II CAUSING TOTAL INTERRUPTION AT 220 KV S/S KWB.

1. Date and Time: 25/06/2017 – 11:55 HRS

4. Elements affected:

Sl.No	Name of Element	Tripping time	Restoration time	LOAD REDUCE
1	KWB#1	11:55 hrs		135 MW
2	KWB#2	11:55 hrs		140 MW
3	KWB#3	11:55 hrs		138 MW
4	DSPM#1	11:55 hrs		200 MW
5	KEB#5	11:55 hrs	12:50 hrs	90 MW
6	KEB#6	11:55 hrs		85 MW
7	220 KV KWB-CHHURI LINE – I & II	11:55 hrs		
8	220 KV KWB-KEB I/C No.- I	11:55 hrs	12:18 hrs	
9	220 KV KWB-KEB I/C No.- II	11:55 hrs		
10	220 KV KWB-DSPM LINE	11:55 hrs		
11	220 KV KEB-DSPM LINE	11:55 hrs	12:16 hrs	
12	500 MVA ICT AT KWB	11:55 hrs		
13	220 KV KWB-MOPKA LINE	11:55 hrs		

COPY TO: (1) THE CE (O&M/S.S) CSPTCL, RAIPUR.

(2) THE CE (LD) CSPTCL, RAIPUR.

Shift Incharge
SLDC, CSPTCL, RAIPUR