

FLASH REPORT

Agency Name/Month-Year/GD or GI- Number

Name of Incident: At 18:40 Hrs on Dated 07-07-2017

Following feeders tripped at 500MVA Transformer 1 charged at SGTPS Thermal power station

1. 400/220kV ICT-I (500MVA) at SGTPS BIRSINGPUR charge at 18:40 on dated 07-07-2017 but it got tripped with following annunciations and all outgoing feeder also tripped.
2. 2. Transformer 500MVA –breaker auto trip, NR RELAY FAULTY, Transformer over flux alarm.
3. 40 MVA STATION transformer No.2 at BIRSINGPUR , SGTPS
4. 220kV BIRSINGPUR –AMARKANTAK CIRCUIT NO.2
5. 220kV BIRSINGPUR- REWA CIRCUIT
6. 220 kV BIRSINGPUR- BIRSINGPUR -4
7. 40 MVA STATION TRANSFORMER NO .1 AT BIRSINGPUR SGTPS

NOTE:- LOAD LOSS NIL